

Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/EZ 442.02/15


Product tested	Gas Detector Series SafEye 700S	Certificate holder	Spectrex Inc. 218 Little Falls Road Cedar Grove, NJ 07009 USA
Type designation	SafEye 701S, 702S, 703S, 721S, 722S, 723S		
Codes and standards	IEC 61508 Parts 1-2 and 4-7:2010 EN 50402:2005+ A1:2008 + AC:2009	EN 50271:2010 EN 50270:2006	
Intended application	Detectors of the gas detector series SafEye 700S can be used for the detection of ambient combustible gases. The gas detector series SafEye 700S complies with the requirements of the relevant standards (SIL 2 acc. to IEC 61508) and can be used in applications up to SIL 2 acc. to IEC 61508.		
Specific requirements	The instructions of the associated User's and Maintenance Manual shall be considered.		
Valid until	2020-05-20		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EZ 442.02/15 dated 2015-05-20.
This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2015-05-20

Certification Body for FS-Products


Dipl.-Ing. Heinz Gall

www.fs-products.com
www.tuvasi.com

 **TÜVRheinland®**
Precisely Right.