

Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/EZ 443.02/15

Product tested Gas Detector Series SafEye 300S **Certificate holder** Spectrex Inc.
218 Little Falls Road
Cedar Grove, NJ 07009
USA

Type designation SafEye 301S, 302S

Codes and standards IEC 61508 Parts 1-7:2010 EN 50270:2006
EN 50402:2005+ A1:2008 + AC:2009 EN 50271:2010

Intended application Detectors of the gas detector series SafEye 300S can be used for the detection of ambient combustible gases. The gas detector series SafEye 300S complies with the requirements of the relevant standards (SIL 2 acc. to IEC 61508) and can be used in applications up to SIL 2 acc. to IEC 61508.

Specific requirements The instructions of the associated User's and Maintenance Manual shall be considered.

Valid until 2020-05-26

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EZ 443.02/15 dated 2015-05-26.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2015-05-26

Certification Body for FS-Products

Dipl.-Ing. Heinz Gall

www.fs-products.com
www.tuvasi.com

TÜVRheinland[®]
Precisely Right.